



T.S. DISASTER RESPONSE AND FIRE SERVICES DEPARTMENT

Office of the Station Fire Officer,  
Fire Station Jeedimetla,  
Dist. Medchal - Malkajgiri.  
Date: 09/06/2025

R. C No. 09 /SFO/JDM/2025-26

To  
M/s. Rajadhani Residential School,  
Near Panchayat Office Nizampet,  
Kukatpally, 500090, T.S

Sir,

Sub: Telangana State Disaster Response and Fire Services Department – Medchal - Malkajgiri Dist.

- Fire Station, Jeedimetla - Danger and Offensive traders - Inspection Report Submitted - Reg.

The above High/Moderate / Low Fire Hazardous Premises inspected on 04/06/2025

The following Fire Preventive measures adopted.

1. ( 01 ) Nos. of Water CO2 Fire extinguishers each of 09 Ltrs.
2. ( 01 ) Nos of Foam fire Extinguishers each of 09 Ltrs.
3. ( - ) Nos of Foam fire Extinguishers each of - Ltrs.
4. ( 03 ) Nos. of CO2 fire Extinguishers each of 4.5 Kgs.
5. ( 01 ) Nos. of CO2 fire Extinguishers each of 02 Kgs
6. ( - ) Nos. of DCP fire Extinguishers each of - Kgs.
7. ( 18 ) Nos of ABC fire Extinguishers each of 06 Kgs.
8. ( 02 ) Nos of ABC fire Extinguishers each of 04 Kgs
9. ( 4+1 ) Nos of Fire Buckets
10. ( 1LKL ) Underground Static water Storage Tank
11. ( 40KL ) Terrace Tank
12. ( ✓ ) Yard Hydrant
13. ( - ) Automatic Sprinkler System
14. ( ✓ ) Manually operated Fire alarm system.
15. ( - ) Automatic Detection and alarm system.
16. ( ✓ ) Hose Reel.
17. ( - ) Wet Riser.
18. Smoking should be strictly prohibited.

19. This premises will be inspected again in the month of Nov, 2026

The above Firefighting equipment found in good working condition.

*V. Rao*  
Secretary - Correspondent  
Rajadhani Residential School  
Affiliated to CBSE 3630027  
Nizampet, Hyderabad, Telangana -90

*Rao*  
PRINCIPAL

RAJADHANI RESIDENTIAL SCHOOL  
AFFILIATED TO CBSE - 3630027  
Nizampet, Hyderabad, Telangana-500090.

RAJADHANI RESIDENTIAL SCHOOL

*Rao*

Founder & President

Founder & President



*Rao*  
Yours faithfully  
STATION FIRE OFFICER  
FIRE STATION JEEDIMETLA,  
MEDCHAL - MALKAJGIRI DIST.